



Government Of West Bengal  
Office Of The Deputy Director  
West Bengal Fire & Emergency Services  
Station Feeder Road, P.O & P.S Siliguri,  
District: Darjeeling, Pin - 734005

Memo no.:FSR/0125186220800008

Date: 01-08-2022

**From:**  
Deputy Director  
North Zone, HQ Wing,  
West Bengal Fire & Emergency Services

**To:** DAVID HARE TEACHERS TRAINING COLLEGE(B.ED)  
MAHANAGAR(NEAR 20 MILE CHECK POST),P.S-GAZOLE,DIST-MALDA

**Sub:** Fire safety certificate for the occupancy of a G+1storied educational Institution under group of Educational in the name of DAVID HARE TEACHERS TRAINING COLLEGE(B.ED) at Premises -Plot No- - 1108, KH No-917, JL No- 164, Mouza- Mahanagar, Under Deotala Gram Panchyat, Vill- Mahanagar (Near 20 Mile Check Post), P.O- Kanta, P.S-Gazole, Dist-Malda.

This is in reference to your application no. 0125189220800048 dated 17-06-2022 regarding the Fire safety certificate for the occupancy of a G+1storied educational Institution under group of Educational in the name of DAVID HARE TEACHERS TRAINING COLLEGE(B.ED) at Premises -Plot No- - 1108, KH No-917, JL No- 164, Mouza- Mahanagar, Under Deotala Gram Panchyat, Vill- Mahanagar (Near 20 Mile Check Post), P.O- Kanta, P.S-Gazole, Dist-Malda.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. Periodical flashing of water in the Hydrant shall be made to maintain the efficiency of the above mentioned system.
3. To eliminate risk of Fire Hazards, Good Housekeeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any ware and tear in there, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and evacuation from the building shall be prepared and displayed at all vulnerable of the building.
6. Regular Mock fire Practices and evacuation drill should be conducted periodically by participation of all the occupants of the building and for this purpose a special crew should be formed.

7. A Crew of trained fire man should be maintained round the clock for the safety of the building.
8. Adequate number of NO SMOKING boards should be displaying surrounding the premises.
9. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
10. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
11. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
12. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction conforming I.S. Specification.
13. The Fire Safety Audit to be conducted at in a regular interval and to record in the Fire Prevention Maintenance register.
14. The Fire Safety Certificate is valid for three years and has to be renewed after three years from the date of issue of this letter As per Govt. of West Bengal Vide Notification No-629\_L Dated-17/04/2018.
15. After three years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services on the basis of performance of all the Life & Fire Safety arrangements and installations of the building.

Signature valid

Digitally signed by ABHIJIT  
PANDEY  
Date: 2022.03.01 12:24:22 IST

Deputy Director  
West Bengal Fire & Emergency Services