



सत्यमेव जयते

Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
English Bazar Fire Station, Ghorapir, Malda. Pin :- 732101

Memo No.: FSR/0125186220800008

Date : 25-07-2025

From :
Divisional Fire Officer
Malda Division,
West Bengal Fire & Emergency Services

To :
DAVID HARE TEACHERS TRAINING COLLEGE(B.ED)
MAHANAGAR(NEAR 20 MILE CHECK POST),P.S-GAZOLE,DIST-MALDA

Sub : Renewal of Fire Safety Recommendation for existing construction of G+1 Storied Institutional Building in the name of style of DAVID HARE TEACHERS TRAINING COLLEGE(B.ED)at the Premises no- MAHANAGAR(NEAR 20 MILE CHECK POST),P.S-GAZOLE,DIST-MALDA.

This is in reference to your AIN 211912506300005792 dated 06-Jun-2025 regarding Renewal of Fire Safety Recommendation for existing construction of G+1 Storied Institutional Building in the name of style of DAVID HARE TEACHERS TRAINING COLLEGE(B.ED)at the Premises no- MAHANAGAR(NEAR 20 MILE CHECK POST),P.S-GAZOLE,DIST-MALDA..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. Installation the following fire safety installation within next 03 months duration from the date of issue of this certificate and the compliance of the same

is to be intimated to this office:-

- Stand by pump of 5 HP is to be installed in the said building.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300005792

2. Driveway must be free of any type of obstruction, for easy movement of Fire Appliances. No Parking, will be allowed on the Driveway.
 3. 'Fire Licence' has to be obtained for the purpose of storing & processing of highly combustible articles.
 4. The Interior finish decoration of buildings shall be made with low flame spread material, conforming to the I.S Specification.
 5. To eliminate risk of Fire Hazards, Good House Keeping both inside and outside of the buildings shall be strictly maintained.
 6. Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
 7. A Fire control room including closed circuit TV system shall to be maintained which observe all the floors of the building.
 8. The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the buildings.
 9. The employees and security staff shall be conversant with installed fire fighting equipments of the buildings and to operate in the event of fire and testing.
 10. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.
 11. Transformer and switch gear shall be protected with automatic CO2 or DCP fire extinguishers conforming I.S. specification.
 12. A crew of trained Fireman should be maintained round the clock for fire safety of the building.
 13. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting Installation in the buildings to keep them in perfectly good working condition all the time.
 14. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduct pipes continuously bonded to the earth.
 15. Electrical ducts shall have to be sealed vertically and horizontally in proper manner.
 16. Periodical flashing of water in the Hydrants pipe line and sprinkler shall be made to maintain the efficient working performance of the maintained system.
 17. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
 18. This Renewal of Fire Safety Certificate is valid for 03 (Three) years on fulfilment of condition, installation of fire safety measurement as per point no. 1 within three 03 months along with a submission of compliance report for the same to this office otherwise this renewal will be treated as automatically invalid, and thereafter has to be renewed within stipulated period from the date of issuance of this letter from the, Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.
- Note:- Any deviation or changes in the nature of use of the buildings in respect of the approved plan drawing without obtaining prior permission from this office, this approval will be treated as cancelled.

Valid Upto : 23-Jul-2028



Signature valid

Digitally Signed.
Name: SHILPA NARAYAN BARMAN
Date: 25-Jun-2018 18:22:43
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300005792